



HANDHOLE

CONDUIT SPECIFICATIONS

1. FOR TRAFFIC SIGNALS ALL CONDUIT WILL BE RIGID GALVANIZED STEEL .
2. CONDUIT FOR FIBER MAY BE EITHER GALVANIZED STEEL OR PVC PLASTIC AND MUST BE APPROVED BY THE ENGINEER.
3. TRACER WIRE WILL BE INSTALLED IN ALL CONDUITS FOR LOCATING PURPOSED.
4. ALL EMPTY CONDUITS WILL HAVE A PULL STRING.
5. CONDUIT WILL BE 24 INCHES DEEP TO THE TOP AT GRADE.
6. A MIN 30 FEET OF WIRE SHALL BE COILED IN ALL HANDHOLES (NOT LOOPED THROUGH).

PREPARED BY: DLZ INDIANA, LLC



Brian M. Smith
3-26-13

APPROVED/REVISED BY THE BOARD OF PUBLIC WORKS & SAFETY

CITY OF MISHAWAKA, INDIANA

| ITEM | REVISION | APPROVED DATE |
|------|--------------|---------------|
| | ADOPTED: NEW | MARCH 2013 |
| | | |
| | | |



TRAFFIC/ELECTRICAL
HANDHOLE

ENGINEERING STANDARDS

SHT. NO.

IX-1