

TABLE OF CONTENTS

STANDARD SPECIFICATIONS

SECTION I – GENERAL NOTES AND CONDITIONS	1
I-1 PREVAILING SPECIFICATIONS	1
I-2 DEFINITIONS	1
I-3 AS-BUILT DRAWINGS	3
I-4 BOND REQUIREMENTS	4
I-5 PERMITS	5
I-6 SAFETY REQUIREMENTS.....	6
I-7 CLEARING OF RIGHT-OF-WAY OR EASEMENTS.....	6
I-8 EXCAVATION	7
I-9 COMPACTION REQUIREMENTS	7
I-10 PROTECTION OF EXISTING UTILITIES	8
I-11 TRENCHING LIMITS	8
I-12 EROSION CONTROL	8
I-13 DVD RECORD AND PHOTO JOURNAL.....	8
 SECTION II – APPROACHES.....	 10
II-1 NEW DRIVE CONSTRUCTION	10
II-2 GRADE CONTROL.....	10
 SECTION III – CURBS, CURB RAMPS, AND SIDEWALK	 10
III-1 CURB AND GUTTER.....	10
III-2 CURB RAMPS.....	10
III-3 SIDEWALK	11
III-4 MISCELLANEOUS CONCRETE	11
 SECTION IV - PAVEMENT.....	 12
IV-1 PREPARATION OF SUBGRADE	12
IV-2 ASPHALT PAVEMENTS	12
IV-3 CONCRETE PAVEMENTS	12
IV-4 PAVED STREET PATCHING	13
 SECTION V – SANITARY SEWERS.....	 15
V-1 SANITARY SEWER PIPE MATERIALS.....	15
V-2 SANITARY SEWER GRAVITY PIPE INSTALLATION.....	15
V-3 SANITARY SEWER TESTING	16
V-4 SANITARY SEWER MANHOLES.....	17
V-5 MANHOLE VACUUM TESTING	17
V-6 SANITARY LIFT STATION.....	17
V-7 SANITARY SEWER FORCEMAIN MATERIALS.....	19
V-8 SANITARY SEWER FORCEMAIN INSTALLATION	19
V-9 SANITARY SEWER FORCEMAIN TESTING	20
V-10 AIR RELEASE VALVES	21
V-11 BUILDING SANITARY SEWER LATERALS	21
V-12 GREASE INTERCEPTORS.....	21

SECTION VI - STORM SEWERS	23
VI-1 FOOTING DRAINAGE DISCHARGE COLLECTION SYSTEM.....	23
VI-2 STORM SEWER PIPE.....	23
VI-3 STORM SEWER CASTINGS.....	26
SECTION VII - UTILITIES.....	26
VII-1 WATER UTILITIES	26
VII-2 UTILITIES IN CASING (JACK/BORE METHODS)	26
SECTION VIII - MAINTENANCE OF TRAFFIC.....	27
VIII-1 STREET SIGNS	27
VIII-2 CONSTRUCTION SIGNAGE.....	28
SECTION IX – TRAFFIC ENGINEERING	28
IX-1 VIDEO DETECTION SYSTEM.....	28
IX-2 OPTICAL PREEMPTION TRAFFIC SIGNAL CONTROL SYSTEM	28
IX-3 SPREAD SPECTRUM RADIO INTERCONNECT	28
IX-4 SIGNAL HEAD SPECIFICATION	29
IX-5 UNINTERRUPTIBLE POWER SUPPLY	29
IX-6 CONTROLLER.....	29
IX-7 SPECIAL TRAFFIC SIGNAL COMPONENT COLOR	30
SECTION IX – LIGHTING/ELECTRICAL.....	30
(Reserved for future)	30

TABLE OF CONTENTS

STANDARD DRAWINGS

SECTION I - GENERAL NOTES AND CONDITIONS

COVER SHEET	I-2
TEMPORARY GRAVEL CONST. ENTRANCE	I-3
INLET PROTECTION GEOTEXTILE BOX	I-4
INLET PROTECTION GRAVEL RING	I-5
INLET PROTECTION SLOTTED BARREL	I-6
TEMPORARY SILT FENCE	I-7
CONTOUR STRAW OR COCONUT WATTLE	I-8
EROSION CONTROL – MODERATE LAND DISTURBING	I-9
EROSION CONTROL – LIGHT LAND DISTURBING	I-10
EROSION CONTROL – CONSTRUCTION SEQUENCE	I-11

SECTION II – APPROACHES

RESIDENTIAL DRIVEWAY APPROACH	II-1
DRIVE CONSTRUCTION WITH DEPRESSED CURB	II-1A
CUL-DE-SAC DETAILS	II-2
TEMPORARY CUL-DE-SAC DETAIL	II-2A
SEWER TAP AS-BUILT	II-2B
PUBLIC STREET APPROACH	II-3
PUBLIC STREET APPROACH WITH SHOULDERS	II-3A
COMMERCIAL DRIVE APPROACH TYPE I	II-4
COMMERCIAL DRIVE APPROACH TYPE IA	II-4A
COMMERCIAL DRIVE APPROACH TYPE II	II-5
COMMERCIAL DRIVE APPROACH TYPE III	II-6

SECTION III – CURBS AND SIDEWALK

CURB DETAILS	III-1
CURB CAPPING DETAIL	III-1A
SIDEWALK CURB RAMP LOC. PLAN & TYPE 1	III-2
SIDEWALK CURB RAMPS TYPE II & NOTES	III-2A
SIDEWALK DETAIL	III-3
CURB BOX SLEEVE ADJUSTMENT/REPLACEMENT	III-4
VALVE BOX ADJUSTMENT/REPLACEMENT	III-5
SURVEY LINE MONUMENT	III-6

SECTION IV – PAVEMENT

TYPICAL SECTIONS	IV-1
PAVEMENT PATCH DETAIL	IV-2
BORE HOLE PAVEMENT PATCH DETAIL	IV-2A
CONCRETE PAVEMENT PATCH	IV-3
UNDERDRAIN TYPICAL SECTION	IV-4
PAVEMENT PATCH WITH FABRIC MEMBRANE OR GEOGRID	IV-5

SECTION V – SANITARY SEWERS

TYPE “A” MANHOLE..... V-1
TYPE “B” MANHOLE..... V-2
TYPE “B” MANHOLE (RESTRICTED HEADROOM) V-3
TYPE “C” MANHOLE..... V-4
PRECAST DROP MANHOLE..... V-5
36” MANHOLE CASTING..... V-6
MISHAWAKA MANHOLE LID DETAIL..... V-7
SEWER SERVICE RISER V-8
TYPICAL CLEAN-OUT V-9
MISCELLANEOUS PIPE DETAILS V-10
BEDDING DETAIL “A” V-11
BEDDING DETAIL “B” V-12
MANHOLE WALL REPAIR DETAIL..... V-13
FORCEMAIN MARKER DETAIL..... V-14
GREASE INTERCEPTOR AND PIPING INSTALLATION V-15
GREASE INTERCEPTOR DETAIL V-16
MANDREL AND PROVING RING V-17

SECTION VI – STORM SEWERS

TYPE “V” MANHOLE..... VI-1
CATCH BASIN VI-2
TYPE “E” INLET VI-3
INLET VI-4
PIPE CATCH BASIN VI-5
PRECAST PERFORATED DRYWELL VI-6
CULVERT INSTALLATION..... VI-7
CONCRETE END SECTIONS..... VI-8
METAL END SECTIONS..... VI-9
PERFORATED PIPE DETAIL..... VI-10

SECTION VII – UTILITIES

PIPE IN CASING DETAIL VII-1

SECTION VIII – MAINTENANCE OF TRAFFIC

STANDARD BARRICADES VIII-1
STREET NAME SIGNS VIII-2
MAINTENANCE OF TRAFFIC VIII-3
MAINTENANCE OF TRAFFIC VIII-4

SECTION IX – TRAFFIC ENGINEERING

(NO DETAILS - RESERVED FOR FUTURE)

SECTION X – LIGHTING/ELECTRICAL

STREET LIGHTING FOUNDATION DETAILS..... X-1

STANDARD SPECIFICATIONS

SECTION I – GENERAL NOTES AND CONDITIONS

I-1 PREVAILING SPECIFICATIONS

- A. The City of Mishawaka Engineering Standards shall consist of these standard specifications and of the City of Mishawaka Standard Drawings, the current issue of the Indiana Department of Transportation Standard Specifications, the current issue of the Indiana Department of Transportation's Standard Drawings, and the current issue of the Indiana Manual on Uniform Traffic Control Devices for Streets and Highways. In the event of any conflict between the City of Mishawaka Engineering Standards and any other documents, the City of Mishawaka Engineering Standards shall prevail.

I-2 DEFINITIONS

Whenever the following abbreviations and terms appear, the intent and meaning shall be interpreted as provided under this Section.

- A. AASHTO: Shall mean the “American Association of State Highway and Transportation Officials.”
- B. IAC: Indiana Administrative Code
- C. ANSI: Shall mean the “American National Standards Institute.”
- D. ASTM: Shall mean the “American Society for Testing and Materials.”
- E. AWWA: Shall mean the “American Water Works Association.”
- F. City: Shall mean the City of Mishawaka and/or designee as assigned by the issuing/permitting authority.
- G. Department of Engineering: Shall mean the Director of Engineering or any representative of the Department of Engineering.
- H. Director: Shall mean the Board of Public Works and Safety or any representative of the Board of Public Works and Safety.
- I. Emergency: Shall mean any event which may threaten public health or safety, including, but not limited to, damaged or leaking water or gas conduit systems, damaged, plugged, or leaking sewer or storm drain conduit systems, damaged underground electrical and communications facilities, or downed overhead pole structures.
- J. Engineer: Shall mean the City Engineer, the Director of Engineering or a designated representative.
- K. Excavate: Shall mean to dig into or in any way remove or physically disturb or penetrate any part of a Right-of-Way.
- L. Facility or Facilities: Shall mean any infrastructure component or tangible asset in the Right-of-Way required to provide utility service or means of transportation.

- M. High Volume/Major Thoroughfare: Shall mean any street or road meeting ANY of the following criteria:
- Traffic volume in excess of 5,000 VPD.
 - Pavement width in excess of 38 feet.
 - Number of lanes in excess of 2.
 - Right-of-Way width 60 feet or greater.
 - Special circumstances temporarily requiring major thoroughfare designation by the City (i.e. major construction along roadway, seasonal or special event, etc.)
- N. INDOT: Shall mean the Indiana Department of Transportation.
- O. Bonded Excavator: Shall mean any person who has submitted a Bond to the City to excavate in public places.
- P. MUTCD: Shall mean the Indiana Manual on Uniform Traffic Control Devices for Streets and Highways.
- Q. NEMA: Shall mean the “National Electrical Manufacturers’ Association.”
- R. Newly constructed, reconstructed, or rehabilitated streets: Shall mean any street that has been newly constructed, reconstructed, or rehabilitated within the past five (5) years.
- S. OSHA: Shall mean the “Occupational Safety and Health Administration.”
- T. Permittee: Shall mean a person who has obtained a permit as required by this ordinance.
- U. Person: Shall mean any natural or corporate Person, business association or other business entity including, but not limited to, a partnership, a sole proprietorship, a political subdivision, a public or private agency of any kind, a utility, a successor or assign of any of the foregoing, or any other legal entity.
- V. Pole Placement: Shall mean any excavation associated solely with a single placement or replacement of a utility pole.
- W. Professional Engineer: Shall mean an engineer licensed and certified in the State of Indiana by the Indiana Professional Licensing Agency.
- X. Public Place: Shall mean any public street, way, place, alley sidewalk, park, square, plaza, or any other similar public property owned or controlled by the City and dedicated to public use, and any dedicated-but-unaccepted street or way.
- Y. Rehabilitation: Shall mean that activity of work on any street that provides structural improvement having a minimum service life of 10 years with minor maintenance, which includes pavement overlay of 1.5 inches minimum depth, and partial or full depth reconstruction.
- Z. Right-of-Way: Shall mean the area on, below, or above a public roadway, highway, street, bicycle lane, and public sidewalk in which the City has an interest, including other dedicated Rights-of-Way for travel purposes and utility easements of the City. A Right-of-Way does not include the airwaves above a Right-of-Way with regard to cellular or other non-wire telecommunications or broadcast service.

- AA. Right-of-Way Occupancy Permit: A Right-of-Way Occupancy Permit shall be obtained from the Department of Engineering for any work completed within the right-of-way. This shall include but not be limited to the following: any type of excavation work, repair work on utilities both above and below grade, any work that requires any disruption to normal traffic flow, maintenance of traffic or lane closures.
- BB. Rules & Regulations: Shall mean the Department of Engineering, through the Board of Public Works and Safety, shall establish rules & regulations governing street excavations and implementing this ordinance. The Director may delegate any or all of the duties hereunder.
- CC. Standards: Shall mean the City of Mishawaka Engineering Standard Specifications and Standard Drawings.
- DD. Substructure: Shall mean the Department of Engineering, through the Board of Public Works and Safety, shall establish rules & regulations governing street excavations and implementing this ordinance. The Director may delegate any or all of the duties hereunder.
- EE. Utility: Shall mean a public utility as defined in IC 8-1-2-1 and as it may be hereinafter amended and shall specifically include the non-regulated activities of such a utility.
- FF. Utility Location: Shall refer to the “Indiana Underground Plant Protection Service” commonly known as “Holey Moley.”

I-3 AS-BUILT DRAWINGS

- A. "As Built Drawings" will be required on all improvements that are to be dedicated to, and accepted by, the City for inclusion in the public infrastructure; or will in any way impact any part of the existing public infrastructure.
- B. “As Built” or record drawings of any sewer construction, sanitary or storm, in the City of Mishawaka shall be provided to the Department of Engineering upon completion of and prior to the City’s acceptance of the project. As-built drawings shall be submitted on plan and profile sheets in digital format (AutoCAD), as well as typical hard copies. Two (2) hard copies shall be submitted.
- C. Requirements for “As-Built” or record drawings:
 1. Each sheet must be signed and sealed by a licensed Professional Engineer.
 2. All elevations given on as-builts shall be per NAVD 88 (North American Vertical Datum).
 3. Indicate the invert and casting elevations of all structures i.e. manholes, catch basins, inlets, etc. Casting elevations on catch basins and inlets will be shown at the flowline.
 4. Indicate the percent of line slope between structures and/or between structures and stubs.
 5. Indicate horizontal location of sanitary laterals and/or taps from the downstream manhole.
 6. Indicate the length of the sanitary laterals and/or taps from mainline sewer including the elevation of the laterals at the property/right-of-way line and offsets if necessary (see sheet II-2B for As-built detail).

7. Indicate the location of all structures i.e. manholes, catch basins, inlets, etc., by stationing.
8. As-built drawings shall indicate the locations of other existing utilities, including but not limited to communications and signals, fiberoptic, telephone, electric and water.
9. As-built drawings shall show all right-of way, easement and property lines. When service taps have been installed, all property information shall be shown (i.e. lot #, address, property owner name).
10. If horizontal location of sewer is per plan, place a check mark (√) followed by per plan next to structure on plan section of sheet.

Example: MH #1√ per plan STA 1+00/10'RT, Line 'M'

11. If vertical location of sewer is per plan, place a check mark (√) followed by per plan next to invert elevation of structure indicated on profile section of sheet.
12. If line slope of sewer is per plan, place a check mark (√) followed by per plan next to line slope information of profile section of sheet.

Example: 360 LFT – 30" sanitary sewer @ 1.00%
√ per plan

13. Any changes on horizontal and vertical location of sewers and any changes on percent of line slope must be shown on plan and profile sections.
14. All information on "As-Built" or record drawings must be neat, concise, and legible.
15. Indicate the composition of pipe, i.e. Clay, RCP, DIP, etc., on profile section of sheet for each run. A "run" being a section of pipe between structures or between structures and stubs.
16. Any other information or data requested by the Department of Engineering personnel must be submitted if requested.

I-4 BOND REQUIREMENTS

- A. Public Works Bond is required for construction in the public right-of-way, which is posted to the office of the Department of Engineering. This Bond is a calendar year bond and is the contractor's responsibility to provide continuations from year to year. This Bond is required to be current in order to obtain City permit to perform any excavation, or other work, in the public rights-of-way of the City.
- B. Maintenance Bond shall be provided by the Contractor that binds themselves to the Owner for the guarantee of the work, material, and conditions of the work completed for any improvements that are to be accepted by the City. The Maintenance Bond amount shall be 10% of the construction value or \$25,000, whichever is greater. The Maintenance Bond shall be provided for a period of three (3) years, from the date of acceptance of such improvements.

- C. Provide all required bonds, per the project specifications, for any work that is completed under contract with the City.

I-5 PERMITS

- A. Permit fees are as set forth in the current City Code of Ordinances.
- B. Obtaining and protecting utility locations are the sole responsibility of the Contractor.
- C. Only licensed and bonded Contractors (Public Works Bond) shall be eligible to obtain a permit to perform any excavation, or other work, in the public rights-of-way of the City.
- D. A Sewer Construction Permit shall be obtained from the office of the Department of Engineering prior to any work associated with the sewer. The sewer work shall include but not be limited to the following: any type of sewer excavation work, new sewer construction or connections, existing sewer repair work and sewer manhole connection or repair work.
- E. A Right-of Way Occupancy Permit shall be obtained from the office of the Department of Engineering prior to any type of work within a City street or right-of-way. Work within the right-of-way that requires a Right-of-Way Occupancy permit shall include but not be limited to the following: any type of excavation work, repair work on utilities both above and below grade, any work that requires any disruption to normal traffic flow, maintenance of traffic or lane closures. In accordance with the City Ordinance a drawing(s) indicating all pertinent information regarding the work to be done (location, purpose, work area, trench width, length and depth, barricades, traffic maintenance plan, duration of work, etc.) shall be submitted to obtain such permit.
- F. Numerous arterial streets in the City are designated as "High Volume Streets" and require a "High Volume Street Cut Permit." A detailed drawing(s), as in item D, above, must be submitted, with particularly close attention to traffic safety and maintenance, to obtain this permit. Three (3) working days are to be allowed for the processing of this permit.
- G. Any work on a state Highway, or within State rights-of-way, requires a permit from the Indiana Department of Transportation Permits Department of the LaPorte District office. Please call (219) 362-6125 for more information.
- H. The construction of any driveway or connection with any City street requires a driveway permit from the office of the Department of Engineering. A Detailed Drawing indicating location of the driveway (distance from any intersection and existing driveways, adjacent and opposite) tapers or radii, the existing and proposed elevations and any other information necessary to properly show the proposed work is to be included on the drawing and become part of the permit.

- I. Comply with all federal, state, and local statutes, rules, regulations, and ordinances related to the proposed work. Obtain any Environmental permits deemed necessary including, but not limited too the following.
 - 1. NPDES “Rule 5” permit.
 - 2. IDEM permit.
 - 3. IDNR permit.
 - 4. Army Corps of Engineers
- J. Obtain any permit required for storm water run-off associated with construction activity and develop, implement and maintain a storm water management plan consistent with the requirements of 327 IAC 15-5-7. Obtain local erosion control permit and submit erosion control plan, if required, in accordance with City ordinance and Section I-12.
- K. Any work on or near City streets requires a Maintenance of Traffic plan consistent with the requirements of Section VIII-2.
- L. Any work within railroad right-of-way shall be in accordance with the specifications and requirements of the railroad having jurisdiction.

I-6 SAFETY REQUIREMENTS

- A. Comply with all federal, state, and local codes and regulations.
- B. Contractor shall have notices posted in prominent locations showing emergency telephone numbers etc., as required by law.
- C. Provide temporary fire extinguishers as required by law.
- D. Provide first-aid kit as required by law.
- E. Contractor shall be responsible for all protection of persons and property in the construction area.
- F. Contractor shall follow all OSHA regulations.
- G. If required, a Health and Safety Plan shall be submitted and on file with the City.

I-7 CLEARING OF RIGHT-OF-WAY OR EASEMENTS

- A. Clearing of Right-of Way or Easements shall consist of clearing, grubbing, removing, and disposal of all vegetation and debris within the limits of the Right-of-Way or Easement. Burning is not permitted.
- B. All existing trees and vegetation that are noted as to remain shall be protected.
- C. Any damage to the natural habitat, vegetation, or objects designated to remain shall be repaired, replaced, or compensated for by the Contractor for no additional payment.
- D. Topsoil Stripping and Stockpiling
 - 1. Stockpile topsoil in areas that are approved by the City of Mishawaka.
 - 2. Dispose of unsuitable or excess topsoil per all local, State and Federal regulations.
 - 3. Provide erosion-control measures for all stockpile areas to prevent soil erosion and discharge of soil bearing water runoff to adjacent properties and walkways.

I-8 EXCAVATION

- A. Emergency Excavation - The office of the Department of Engineering is to be notified as soon as possible in the event of any emergency excavation, followed by a permit application.
- B. Initial Excavation
 - 1. The Contractor is responsible for the placement of all safety lighting, barricades, and warning signs.
 - 2. Initial access hole shall be cut only as large as required to perform work.
- C. Any excavation undertaken or authorized by this ordinance shall comply with all with requirements per the Indiana Code.

I-9 COMPACTION REQUIREMENTS

- A. The minimum soil compaction requirements for backfill material and pavement subgrade will be as indicated below. The moisture content shall be controlled within -2 and +1 percentage points of optimum moisture content. Maximum density and optimum moisture content shall be determined in accordance with the standard Proctor test ASTM D-698 and AASHTO T 99 using method A for soil and method C for granular materials.

Subgrade under pavement and curbs	100%
Topsoil used in all but the top six inches (6") of fill	90%
Existing ground receiving fills.	95%
Backfill in pipe and conduit trenches under pavements and curbs.	95%
All other areas receiving fill.	95%

- B. Compaction Testing Frequency
 - 1. A minimum of (1) compaction test will be required on the backfill for each sewer pipe and water main pipe transverse run that is under the pavement or concrete curb. A minimum of three (3) compaction tests will be required on the backfill for sewer pipe or water main pipe run. A pipe run is the length between structures or valves.
 - 2. A minimum of one (1) compaction test will be required per 500 square yards of roadway, per lift of earth fill or subgrade. The minimum number of tests is 10 each.
 - 3. Location of the compaction tests will be selected by the Engineer.

I-10 PROTECTION OF EXISTING UTILITIES

- A. Protect existing utilities during construction.
- B. Notify the City of Mishawaka and their representatives not less than two days in advance of any proposed utility interruptions.
- C. Contact Indiana Underground Plant Protection Service (IUPPS) at 1-800-382-5544 for utility location services for the construction project area a minimum of 3 working days prior to any excavation. This does not relieve the Contractor of notifying utility owners who may not be part of the IUPPS alert system.
- D. Demolish and remove completely any underground utilities indicated to be removed. Coordinate with the utility companies to shut off services if lines are active.

I-11 TRENCHING LIMITS

- A. Excavate trenches to indicated gradients, lines, depths, and elevations, as noted on the plans.
- B. Excavate trenches to allowable widths to provide a working clearance on each side of pipe or conduit. Excavate trench walls vertically from trench bottom to 12 inches higher than top of pipe or conduit, unless otherwise indicated.
- C. Excavate and shape trench bottoms to provide uniform bearing and support of pipes and conduit. Shape subgrade to provide continuous support for bells, joints, and barrels of pipes and for joints, fittings, and bodies of conduits. Remove projecting stones and sharp objects along trench subgrade.

I-12 EROSION CONTROL

- A. Erosion and Sediment Control is required for all work. It shall be the responsibility of the Contractor during construction to prevent sediment in storm water runoff from leaving the construction site.
- B. The Contractor shall be responsible to comply with all aspects of the City of Mishawaka "Erosion Control Ordinance" including permitting and bonding as required.
- C. The erosion control permitting measures contained herein do not relieve the Contractor from compliance with all aspects of 327 IAC 15-5, Rule 5, "Storm Water Run-Off Associated with construction activity."

I-13 DVD RECORD AND PHOTO JOURNAL

- A. Any work completed within the City Right-of-Way may require a video record and/or photo journal. Contact the Department of Engineering to determine if a video record or photo journal is required. All work completed for the City will require a video record and photo journal.

- B. All work to complete the video record and the photo journal shall be done in a professional manner and preferably by a professional photographer/videographer. Any submitted video or photography that lacks professional quality will be required to be re-shot using a business that specializes in documentary video/photography.
- C. One original and one copy of both the DVD and the Photo Journal shall be forwarded to the Department of Engineering for review prior to beginning construction and shall become the property of the City.
- D. All DVD's shall be labeled with the name "City of Mishawaka" and the name of the Contractor. The photo journal shall be in color and professionally labeled showing the name "City of Mishawaka" and the name of the Contractor.
- E. The Contractor shall keep one copy of both the DVD and the Photo Journal for their records.
- F. The Video Record shall be submitted in a DVD format, professionally completed video recording of the entire project area to clearly show all features located within and adjacent to the right-of-way. This includes driveways, street pavements, encroachments in the right-of-way, shrubs, trees, fences, etc., prior to the start of construction. The DVD shall include close-ups of the foundations of each structure located adjacent to the right-of-way. The DVD shall cover three sides of the foundation, the side adjacent to the right-of-way and the two sides perpendicular to the right-of-way. Audio identification shall be included to describe each property, i.e. "You are seeing 200 E. Main Street the east side of the property" also every effort shall be taken to give some visual reference of each shot (panning to an address or street sign). The camera work must be reasonably stable (the use of a tripod may be necessary). The recording shall include a time and date code displayed at one corner of the screen.
- G. The Photo Journal shall be made of as many pictures as necessary to clearly show all visible cracks, foundation faults, and sidewalk and driveway cracks of each property. A minimum of one (1) picture shall be provided for each of the three sides of the structure or foundation to show the existing condition. All fences, trees and landscaping shall be included in at least one (1) of the photos. Photographs shall be made with a digital camera with at least 6 megapixels. Photographs shall be in color, 8-inch x 10-inch with a tape or scale to provide registration of photograph for any existing damage. Photographs shall be taken in sufficient lighting to provide high quality details. Photographs shall include the date taken in one corner and an address or location identifier label. The photos for a specific address and location shall be in its own folder.

SECTION II – APPROACHES

II-1 NEW DRIVE CONSTRUCTION

- A. All new and reconstructed drives shall comply with Standard Specification Section IV-1 Preparation of Subgrade and IV-3 Concrete Pavements.
- B. Construct driveway per standard details II-1, II-1A, II-4, II-4A, II-5, and II-6.
- C. The minimum and maximum width of driveways shall comply with standard details II-4 through II-6.
- D. New drives constructed in areas of existing roads with curb and gutter are required to maintain the existing gutter line through the limits of the drive by depressing the existing curb, as shown in standard detail II-1A. The gutter should run continuously through the drive approach.
- E. In areas of new road construction, depressed curb shall be installed through the limits of all drives, as shown in standard detail II-1A. The gutter should run continuously through the drive approach.
- F. Expansion and contraction joints are required.

II-2 GRADE CONTROL

- A. Grade control shall be set by one of the following methods:
 - 1. Using a string line, set grade stakes at a minimum of 25 feet on center.
 - 2. Using a laser, set grade stakes at every grade break.
- B. Provide additional control to insure forms are placed such that positive drainage by gravity flow will be obtained.

SECTION III – CURBS, CURB RAMPS, AND SIDEWALK

III-1 CURB AND GUTTER

- A. Backfilling
 - 1. Shall not begin until after concrete has cured for 72 hours.
 - 2. Shall match the surrounding grade and be reseeded or sodded.
- B. Contractor must remove any damaged section of curb to the nearest joint.
- C. Drainage outlets such as roof drains or underdrains are prohibited at the curb.
- D. Restoration of street pavement areas damaged by curb removal shall be restored to the existing material and thickness.

III-2 CURB RAMPS

- A. Concrete curb ramps including flared side and rolled edges shall be 6" concrete.
- B. Curb ramps located at intersections shall be constructed per the standard details III-2 and III-2A, including the 2' x 4' truncated dome detectable warning panel.

- C. Detectable warning panels shall be for any new construction or reconstruction of curb ramps, as manufactured by Armor Tile from an epoxy polymer composite material meeting a compressive strength of 28,800 pounds per square inch, in accordance with ASTM D 695-02a, or approved equal and shall be installed in accordance with the manufacturer's recommendations.
- D. The acceptable colors for detectable warning panels will include:
 - 1. Colonial Red (Federal Color No. 20109)
 - 2. Or as approved by the Engineer.
- E. The detectable warning surface shall be located so that the distance to the near edge of the curb line is 6" minimum and 8" maximum.
- F. Drainage inlets shall be located uphill from curb ramps to prevent water ponding at the path of travel.
- G. The bottom edge of the curb ramp shall be flush with the edge of the adjacent pavement.
- H. Landing areas at the top of curb ramps shall have a maximum cross slope of 50:1 in any direction. When site infeasibility precludes construction of a landing area of 50:1 in any direction, the slope perpendicular to the curb face shall not exceed 50:1.
- I. Minimum width of curb ramp is 4'-0" per current ADA standard.
- J. Grooves are to be placed behind the detectable warning panel in, accordance with standard detail III-2.
- K. Curb ramps located at any other location other than intersections (such as at driveways) shall be constructed per details III-2 and III-2A without detectable warning panels. No mid-block ramps are permitted.

III-3 SIDEWALK

- A. Expansion joints are required at intervals not to exceed 50 feet for five-foot sidewalk.
- B. Specify placement of expansion joints for sidewalk around utility poles, which may project out into the sidewalk, around hydrants and manhole frames, walls, and between sidewalk and buildings abutting said sidewalk.
- C. Where sidewalk is being replaced, sawcut and join the walk to the nearest joint of the existing improvements. If existing adjacent concrete slabs not scheduled for replacement are damaged by the Contractor's operation, the Contractor shall replace the concrete to the next joint at no cost to City. Repair or removal of any panel of sidewalk shall be removed to the nearest joint regardless of property line.

III-4 MISCELLANEOUS CONCRETE

- A. All work and materials related to the construction of driveways, sidewalks, curb ramps, curb and gutter, and curbing are to be in accordance with the current Indiana Department of Transportation Standards Specifications.

SECTION IV - PAVEMENT

IV-1 PREPARATION OF SUBGRADE

- A. The subgrade shall be shaped to the required grade and sections, free from all ruts, corrugations, or other irregularities, and uniformly compacted and approved in accordance with Section 207 of the INDOT Standard Specifications.
- B. Surfaces on which a mixture is placed shall be free from objectionable or foreign materials at the time of placement.
- C. If unsuitable soils are encountered, they shall be addressed in accordance with Section 203.05 and 203.16 of the INDOT Standard Specifications or as required by the City Engineer.
- D. Preparation of subgrade shall be in accordance with Standard Specifications section I-8 and I-9.

IV-2 ASPHALT PAVEMENTS

- A. All materials are to be in accordance with the current Indiana Department of Transportation Standards Specifications: Section 402.
- B. The contractor shall submit a job mix formula for approval five (5) working days prior to any mix placed. The contractor will not be allowed to proceed with the placement of asphalt without an approved job mix formula. The contractor shall notify the city 48 hours prior to placing any asphalt.
- C. The HMA shall be supplied from a certified HMA plant in accordance with ITM 583 - Certified Volumetric Hot Mix Asphalt Producer Program. The HMA shall be transported and placed in accordance with the current Indiana department of Transportation Standards Specifications: Section 402.
- D. If the Engineer requests pavement cores, the Contractor shall, within one workday, clean, dry, and refill the core holes in accordance with Standard Specification Section IV-4-A Bore hole Restoration.

IV-3 CONCRETE PAVEMENTS

- A. All materials are to be in accordance with the current Indiana Department of Transportation Standards Specifications.
- B. Class "A" Concrete (because of its frequent use, is defined here) shall have 6 sacks (94 lbs.) of cement per cubic yard of concrete and 6 gallons of water, maximum, per sack of concrete. Fly Ash May Be Used in Concrete Mix in Accordance With Sections 702.05 and 901.02 of The Indiana Department of Transportation Standard Specifications.
- C. Pavement joints shall be in accordance with the current Indiana Department of Transportation Standard Specifications.
- D. Cold Weather Concrete Protection
 1. Contractor will assume full responsibility for placing concrete and for all damage caused by freezing.
 2. Do not place concrete on frozen materials.

3. When air temperature is at or below 40 degrees F and decreasing placement of concrete shall be discontinued, and cannot begin again until the air temperature has reached 35 degrees F and is rising.
 4. The contractor shall provide the necessary equipment and materials to prevent the concrete from freezing prior to attaining opening to traffic strengths, in accordance with INDOT Standard Specification 502.11.
- E. Protection
1. Protect concrete work against injury from elements and defacement of any nature, including vandalism during construction operations.
 2. Provide protection of placed concrete from vandalism, wind, temperature extremes, and loss of moisture.
 3. Do not permit concrete to freeze. Protect by covering with insulated blankets.
 4. Remove and replace any damaged concrete as directed by the Engineer.
- F. Immediately after the finishing operations, the entire surface of the newly placed concrete shall be covered and cured in accordance with INDOT Standard Specification section 504.04. Usually a white pigmented curing compound is utilized and is preferred by the City.
- G. Utilize signs, barricades, flag persons or any other equipment and personnel to make safe construction areas within the City right-of-way, in conformance with current MUTCD standards.
- H. Removals
1. All excavated areas shall be protected at all times.
 2. Disposal of debris resulting from clearing or removal operations shall be removed from site immediately to an off site area.
 3. No stockpiling or on site containers will be allowed.
- I. If the Engineer requests pavement cores, the Contractor shall, within one workday, clean, dry, and refill the core holes in accordance with Standard Specification Section IV-4-A Bore hole Restoration.

IV-4 PAVED STREET PATCHING

- A. Bore Hole Restoration
1. All bore holes made in existing pavement for soil investigation or pavement coring shall be restored in accordance with Standard Detail IV-2A
- B. Temporary Patch
1. If conditions do not allow the placement of a permanent concrete patch, a temporary asphalt patch shall be allowed. Temporary Patches Shall Be a Minimum Depth of 4" For Local and Collector Streets and a Minimum Depth of 8" for Arterial Streets.
 2. When a temporary patch is to be in place for more than 24 hours the permittee shall furnish the office of the Department of Engineering with the name and phone number of the party responsible for after hours maintenance.

C. Flowable Backfill

1. Shall be a workable mixture with the following properties:

Minimum Unconfined Compressive Strength at 28 days	50 psi
Maximum Unconfined Compressive Strength at 28 days	150 psi
Minimum Fill Spread Diameter at time of placement	8 in.

2. Flowable Backfill shall not be subject to load nor disturbed by construction activities until the penetration resistance testing, in accordance with INDIANA TEST METHOD (ITM) 213, meets the following requirements:

Concrete Pavement	70 psi
All Other Applications	1200 psi

3. Do not place on frozen ground.
4. Protect from freezing until material has set.
5. Do not place into or through standing water, unless approved by the Engineer.
6. Properly attach or anchor all parts and materials that are to remain in the excavation to prevent objects from floating.

D. Weather Limitations

1. Unless special permission is obtained, no permanent patches shall be placed between November 1st and April 1st. During these periods, a durable temporary patch shall be placed in the original access hole.
2. The maintenance of this temporary patch shall be the sole responsibility of the permittee. The permittee shall provide the office of the Department of Engineering with the name and telephone number of the party responsible for the maintenance of the patch.

E. Permanent Patch Installation

1. If concrete is used as a patch in an area of existing asphalt pavement, the concrete shall be integral dyed with Lamp Black Dye.
2. Concrete patches will be placed 8 inches thick, or to a depth to match the existing pavement, whichever is greater.
3. Any patches placed on high volume or major arterial roads shall be a minimum of 10 inches thick, or to a depth to match the existing pavement, whichever is greater.
4. Refer to standard detail sheets IV-2 and IV-3 for more information.

SECTION V – SANITARY SEWERS

V-1 SANITARY SEWER PIPE MATERIALS

- A. Sanitary Sewer (Non-Pressure Gravity Sewer) shall be one of the following:
 - 1. Vitrified Clay - ASTM C700
 - 2. PVC (Polyvinyl Chloride) - ASTM D-3034 for SDR 35 and SDR 26 for 15” diameter and smaller pipe. ASTM F-679, T-1 wall thickness, for pipe larger than 15” diameter. Joints and Fittings shall conform to ASTM D-3212 or ASTM D-2464.
 - 3. Ductile Iron Pipe ASTM A746, with cement lining per AWWA C104.
- B. Sanitary Sewer shall meet the following for depth of bury:

SANITARY SEWER GRAVITY PIPE

Depth (Ft)	Ductile Iron Pipe (Pressure Class)	PVC (SDR)	
	350	35	26
5 - 10	X	X	
10 - 14	X	X	
15 - 19	X		X
20 - 24	X		

V-2 SANITARY SEWER GRAVITY PIPE INSTALLATION

- A. All sanitary sewers shall be designed and installed in accordance with the “Recommended Standards for Wastewater Facilities” by the Great Lakes Upper Mississippi River Board of State and Provincial Health and Environmental Managers. All sanitary sewer extensions shall be approved by the Indiana Department of Environmental Management and the City of Mishawaka, Board of Public Works and Safety.
- B. All sewer pipes shall be laid using a laser beam method to control alignment. All sewer pipes shall be laid true to both horizontal and vertical alignment, and will be subject to review by the Owner and Engineer. Pipes that do not “Lamp” shall be removed and reinstalled to true line and grade.
- C. Commence laying gravity sewer pipe at the lowest point on a section of line and lay pipe with the bell ends uphill.
- D. New pipe must match the pipe to which it is being connected. All of the pipes herein permitted shall be connected to a concrete manhole.
- E. Prior to making connections at pipe joints and manholes, clean and dry all surfaces of pipe joints and joining material. Use materials as recommended by the manufacturer.
- F. Follow the Indiana Department of Environmental Management (IDEM) standards for separation of sanitary sewer and water distribution systems.

- G. A permanent video recording, of any sanitary sewer constructed in the City or connected to the City's sewer system, shall be conducted by the City of Mishawaka's Sewer Maintenance Department. All video recording shall be completed upon the submittal and approval of the as-built drawings.
- H. The Contractor, upon completion of installation of the sewer, shall give written notification to the Department of Engineering.
- I. The office of the Department of Engineering shall be notified at least 48 hours in advance of any testing, in order to be able to witness the tests. Tests for sanitary sewers shall include but not be limited to infiltration, exfiltration, and deflection.
- J. Sanitary sewer service laterals shall be installed per Section V-11 of these specifications.
- K. Installation of all PVC sanitary sewer pipe shall conform to ASTM D2321.
- L. Underground detectable warning tape shall be placed above the sanitary sewer approximately 2-feet below finished grade. Tape to be 2" wide metallic lined with the wording "CAUTION SEWER LINE BURIED BELOW" continuously printed.
- M. The installation of sanitary sewer pipe, within a casing, by jack/bore method shall be per Section VII-2.

V-3 SANITARY SEWER TESTING

- A. Maximum allowable infiltration rate is 100 gallons per inch diameter per mile of sewer per day. Manholes, if tested separately, shall have a maximum allowable infiltration rate of 0.1 gallons per hour per foot of diameter per foot of head.
- B. All flexible sewer piping shall be subject to deflection testing. The maximum acceptable pipe deflection after installation is five percent (5%) of the nominal pipe diameter. The pipe shall be tested by the contractor 30 days or greater after the installation is complete and prior to permanent pavement placement. The deflection test shall be completed with a 9-point mandrel for maximum deflection. The mandrel shall be pulled manually and no force pull on the mandrel will be permitted. The deflection test shall be witnessed and certified by a Professional Engineer and submitted to the office of the Department of Engineering. The Contractor shall provide the Engineer with a proving ring to verify the mandrel size. If the pipe fails the deflection test, the pipe shall be excavated, removed, and discarded. New pipe shall be installed and retested per the above.
- C. All non-rigid sewers to be stiffness certified. The pipe stiffness shall be a minimum of 46 psi.
- D. All sanitary sewer piping shall be subject to a low-pressure air test. Vitrified Clay Pipe (VCP) and Ductile Iron Pipe shall be tested in accordance with ASTM C 828-03. Plastic piping shall be tested in accordance with ASTM F1417-92. The test shall be witnessed and certified by a Professional Engineer and submitted to the office of the Department of Engineering.
- E. The office of the Department of Engineering shall be notified 48 hours in advance of any testing in order to have the option of witnessing the test. If witnessed by the office of the Department of Engineering, the City representative shall sign the testing documents the day of the test.

V-4 SANITARY SEWER MANHOLES

- A. Manholes shall be constructed per the standard details for the type and size shown on the drawing.
- B. Manhole frame and lid shall be a Neenah R-1642 or approved equal. Use a Mishawaka Manhole Lid, Detail V-7, if designated by the City. Use a 36" Manhole Casting, Detail V-6, if designated by the City.
- C. Manholes shall be constructed per ASTM C478 with joints meeting requirements of ASTM C443.

V-5 MANHOLE VACUUM TESTING

- A. The test shall be performed per ASTM C 1244 on all Type A and Type B manholes.
- B. Furnish, install, and operate all equipment, and materials, including meters, gauges, fuel, bulkheads, water and accessory equipment and all manpower for the test.
- C. The test shall be witnessed and certified by a Professional Engineer and submitted to the office of the Department of Engineering.
- D. If the test fails, the Contractor shall determine the cause, and then repair/replace the manhole to the satisfaction of the Engineer. The test shall be repeated until it is successful.
- E. The office of the Department of Engineering shall be notified 48 hours in advance of any testing in order to have the option of witnessing the test. If witnessed by the office of the Department of Engineering, the City representative shall sign the testing documents the day of the test.

V-6 SANITARY LIFT STATION

- A. The requirements for a sanitary lift station shall not be limited to the following specifications. Contact the Department of Engineering for more detailed specifications and requirements for a sanitary lift station.
- B. Description:
 - 1. Lift Station shall be a factory-built dry pit-wet well type sewage lift station complete with precast concrete wet well and all power and other services.
 - 2. A security fence and access road shall be provided.
 - 3. An exterior electrical panel with a permanent emergency generator with automatic transfer switch shall be provided.
- C. Submittals:
 - 1. The lift station shall not be released for fabrication until reviewed shop drawings and design calculations have been approved and released by the Department of Engineering.
 - 2. Design calculations for the lift stations shall be certified by a registered Professional Engineer.

D. Products and Installation:

1. The Contractor shall furnish and install one factory-built automatic pumping station. The station shall be complete with all needed equipment factory-installed in a welded steel chamber with welded steel entrance tube and with maintenance lift to provide access. The lift station shall be manufactured by Smith & Loveless, Inc. or approved equal.
2. The principal item of equipment shall include two vertical, close coupled, motor driven, non-clog sewage pumps; valves; internal piping; central control panel with circuit breakers; motors starters; automatic pumping level controls; lighting; sump pump; ventilator; dehumidifier and all internal wiring.
3. The Contractor shall furnish and install a pump control panel mounted within a NEMA Type 1 enclosure, fabricated of steel and reinforced as required. All circuit breakers, motor-starters, reset buttons and pump control switches shall be mounted so that they are operable without opening the high voltage cabinet.
4. The Contractor shall furnish and install a level transducer to control pump operation by the level of the sewage in the wet well. The transducer shall be suspended by a stainless steel cable or a pipe mounted within the wet well. The transducer shall produce a 4-20 ma signal that will feed into the pump controller.
5. The Contractor shall furnish and install a secondary level control system consisting of a Siemens CB1T redundant float control along with two (2) floats.
6. The Contractor shall furnish and install a pump controller. The controller shall be a factory installed LC-150 controller by Siemens or approved equal.
7. The Contractor shall furnish and install a Remote Telemetry Unit (RTU) at the lift station. The RTU shall be housed above ground in a NEMA 4X enclosure and shall be a Siemens Series S-216(or current model), or approved equal.
8. The Contractor shall coordinate the necessary interface contacts between the pump control panel and the telemetry panel with the manufacturers.
9. The Contractor shall provide the lift station with a radio antenna to be installed above grade adjacent to the lift station in a suitable location. The antenna should be mounted per the manufacturer's recommendations as approved by the Department of Engineering. The antenna height shall provide line of sight transmission to a designated location as set by the Department of Engineering.
10. The Contractor will be responsible for the following:
 - a. Modifications to master computer software to accept the new station.
 - b. Establishing stable communication from the lift station to the WWTP master telemetry computer.
 - c. The Contractor shall coordinate the above with Mishawaka Utilities Wastewater Division.

11. The telemetry equipment shall be furnished and installed and shall be integrated with the pump control panel and the LC-150 controller, i.e., 4-20 mA output signals.
12. Substitution of equipment other than that stated will not be accepted without prior approval from the Department of Engineering.

V-7 SANITARY SEWER FORCEMAIN MATERIALS

- A. Ductile Iron Pipe – Pipe, fittings, and gaskets shall conform to ANSI/AWWA A21.51/C151, ANSI/AWWA A21.10/C110, and ANSI/AWWA A21.11/C111. The ductile iron pipe and joints for the sanitary forcemain shall be plain joints in straight runs and restrained joints at bends and fittings with thrust blocking. Restrained joints shall conform to American Cast Iron Lok-Ring Joint, U.S. Pipe TR Flex, or equal. The pipe shall be pressure class 350. The Ductile Iron Pipe shall have a cement mortar lining with a bituminous seal coat conforming to the requirements of ANSI/AWWA A21.4/C104
- B. High Density Polyethylene (HDPE) Pipe – The use of HDPE pipe shall be upon Engineer’s approval only. HDPE pipe shall conform to ASTM D3350 with a minimum cell classification of PE345464C. The pipe shall have a nominal DIPS (Ductile Iron Pipe Size) OD (Outer Diameter) unless otherwise indicated. The DR (Dimension Ratio) shall be no greater than DR 11 classification. HDPE fittings shall be in accordance with ASTM D 3261. The designer shall determine the pipe thickness required, based on the installation methods and the live and dead loads.

V-8 SANITARY SEWER FORCEMAIN INSTALLATION

- A. All sanitary sewers shall be designed and installed in accordance with the “Recommended Standards for Wastewater Facilities” by the Great Lakes Upper Mississippi River Board of State and Provincial Health and Environmental Managers. All sanitary sewer forcemains shall be approved by the Indiana Department of Environmental Management and the City of Mishawaka, Board of Public Works and Safety.
- B. Prior to making connections at pipe joints and manholes, clean and dry all surfaces of pipe joints and joining material. Use materials as recommended by the manufacturer.
- C. Concrete thrust blocking shall be provided at all changes in directions. Concrete thrust blocking anchors shall bear against undisturbed earth. Restrained joints shall be used in combination with concrete thrust blocking. Restrained joints shall be placed at fittings upstream and downstream of the fitting to be anchored.
- D. Follow the Indiana Department of Environmental Management (IDEM) standards for separation of sanitary sewer and water distribution systems.
- E. The Contractor, upon completion of installation of the sewer, shall give written notification to the Department of Engineering.
- F. The office of the Department of Engineering shall be notified at least 48 hours in advance of any testing, in order to be able to witness the tests.

- G. The locations of buried sanitary sewer forcemains shall be identified with above ground markers located at 400 feet intervals and at all changes in horizontal alignment. Underground detectable tracer wire, Type TW insulated #12, shall be placed above the forcemain and connected to a terminal located within each marker. The markers shall be Rhino 2 Terminal Triview Test Stations, model TVTI5YGB2 or approved equal. The markers shall have green decals with white lettering that reads "Warning Sewer Forcemain" and shall have the phone number of the Mishawaka Sewer Department: 258-1619. Refer to Detail V-14 in the Standard Drawings.
- H. The installation of sanitary sewer forcemains, within a casing, by jack/bore method shall be per Section VII-2.

V-9 SANITARY SEWER FORCEMAIN TESTING

- A. Leakage and Pressure Tests shall be witnessed and certified by a Professional Engineer and submitted to the office of the Department of Engineering. Contractor shall notify the City and the Engineer within 48 hours of testing to allow test to be witnessed.
- B. The Contractor shall be responsible for providing all equipment and tools necessary to perform pressure tests and leakage tests. Tests shall be per the following:
 - 1. Supply water, install and operate the pumps, calibrate gauges and meters and supply all necessary manpower and apparatus for the test.
 - 2. Hydrostatic Pressure Test: After the line has been backfilled and at least seven (7) days after the last concrete anchor block was poured (if applicable), hydrostatic pressure test shall be performed. Carefully fill the system with water at a velocity of approximately one foot (1') per second while necessary measures are taken to eliminate all air. After the system has been filled, raise the pressure by pump to test the greater of 1.5 times the working pressure or 90 psi. Measure pressure at lowest point in system with gauge compensated for elevation. Maintain this pressure for at least two hours. If pressure cannot be maintained, determine the cause, repair, and repeat the test until successful. The method of repair shall be approved by the Engineer.
 - 3. The leakage test shall be conducted concurrently with the pressure test. Leakage shall be determined with a calibrated test meter furnished by the Contractor. Leakage is defined as the quantity of water required to maintain a pressure within 5 psi of the specified test pressure, after air has been expelled and the pipe filled with water.
 - 4. Leakage shall not exceed 10 gallons per day per mile per inch of diameter specified. If leakage exceeds the specified limits, the Contractor shall find and repair the leaks and repeat the test until successful.
 - 5. All visible leaks shall be repaired regardless of amount of leakage.

V-10 AIR RELEASE VALVES

- A. Air Release Valves shall be installed upon Engineer's approval only. Air Release Valves shall be installed at each significant high point where air could become trapped. The air release valve shall be installed in a manhole structure with provisions made for draining the structure, odor control and for an exhaust pipe. Forcemains shall be designed to minimize the number of air release valves.

V-11 BUILDING SANITARY SEWER LATERALS

- A. All building sewers shall conform to the Indiana Plumbing Code.
- B. The building sanitary sewer service lateral shall connect to the public sewer mainline per the Standard Details.
- C. Contractor shall obtain all necessary permits needed for work within the Right-of-Way or sanitary sewer easement. Service connections to mainline sewers shall require a permit and tapping fees per the City requirements.
- D. One service lateral connection per parcel. If any commercial or industrial parcels have more than one building to connect, a sewer main extension is required and shall be approved by the Department of Engineering. Inside drop connections to manholes will not be permitted.
- E. Building sewer service riser installed for future connections shall be terminated at the street right-of-way or easement and shall be properly plugged to ensure a watertight seal.
- F. A clean-out shall be installed adjacent to all building structures. Clean-outs shall also be installed every 100 LFT of sanitary service piping as well as at any change in direction that results in a total deflection of 90 degrees.
- G. The minimum allowable inside diameter for building sewer laterals shall be six inches (6"). Any service connection servicing more than one (1) building shall be a minimum of eight inches (8") inside diameter and connect to a manhole structure.
- H. All six-inch (6") service lateral connections shall be installed with a wye fitting.
- I. All sanitary service lateral piping and wye fittings shall be PVC SDR 35 with gasketed joints unless otherwise indicated.
- J. Installation of all PVC sanitary pipes shall conform to ASTM D2321.
- K. Modifications or changes to the above shall be approved by the Department of Engineering.

V-12 GREASE INTERCEPTORS

- A. Grease Interceptors shall be required for the following types of new building developments, existing buildings with new kitchen additions, a building undergoing a change in ownership/occupancy or any building/facility experiencing difficulty achieving compliance with the maintenance and/or wastewater discharge limitations:
 - 1. All non-residential developments involved in food preparation, processing, and service of food or food products.

2. A Multi-family residential development that will, or has the potential to, discharge grease, oil, or similar substances, having a quantity and characteristics above that of a normal family residential waste, to the sanitary sewer.
 3. Any development or building that will, or has the potential to, discharge grease, oil, or similar substances, having a quantity and characteristics above that of a normal family residence waste, to the sanitary sewer.
- B. Installation of the grease interceptor shall be downstream of all kitchen drains or grease-laden equipment drains and in a location readily and easily accessible for cleaning and inspection purposes.
 - C. Grease interceptors shall be constructed with a minimum of one (1) baffle on both the inlet and outlet sides.
 - D. Grease interceptors are to be installed at a minimum distance of ten (10) feet from sink and twenty (20) feet from dishwashers to allow for adequate cooling of the wastewater. Water temperatures must be less than 120 degrees prior to entering the grease interceptor.
 - E. Each building or facility shall have a separate individual grease interceptor.
 - F. A sample port or manhole shall be provided downstream of the grease interceptor. The opening shall be a minimum of ten (10) inches to allow for sampling access. Refer to Detail V-15 in the Standard Drawings.
 - G. Grease interceptors shall be sized based on the following calculations:

Grease Interceptor Sizing Calculations

$$\text{Tank Size (in gallons)} = \frac{\text{Meals Served During Peak Hour}}{\text{Hour}} \times \text{Waste Flow Rate Factor} \times \text{Retention Time Factor} \times \text{Storage Factor}$$

Meals Served During Peak Hour

$$\text{Meals Served During Peak Hour} = \text{Seating Capacity} \times \text{Peak Factor}$$

- a. Peak Factor for Fast Food Restaurants 1.33
- b. Peak Factor for all other Food Service Types 1

Waste Flow Rate Factor

- a. Commercial kitchen with dishwashing machine 6
- b. Commercial kitchen without dishwashing machine 5
- c. Single service kitchen 2
- d. Sink waste only 1

Retention Time

- a. Commercial kitchen waste 2.4
- b. Single service kitchen 1.5

Storage Factor

- a. Fully equipped commercial kitchen having
 - 8-hour operation 1
 - 16-hour operation 2
 - 24-hour operation 3
- b. Single service kitchen 1.5

- H. The sizing method described above is intended as guidance in determining the grease interceptor size. It is the responsibility of the property owner and/or contractor to insure that the appropriate size interceptor is installed to meet the level of treatment needed. Refer to the Grease Interceptor Detail, Detail V-16 in the Standard Drawings.
- I. Regardless of the above sizing formula, the minimum size grease interceptor shall be 750 gallons wherever possible.
- J. Any establishment that proposes the use of an alternate sizing technique or procedure that results in an interceptor less than the 750 gallon recommendation must submit a request to the City. The proposal shall include calculations, data, drawings, and any other information to support the installation of the proposed grease interceptor. A licensed Professional Engineer shall design and sign the proposal.
- K. In the circumstance of a “single service kitchen” with no food preparation (heat/serve only), i.e. concessions stands, a minimum 50 gallon per minute (gpm) flow rated or a 100 pound grease retention mechanical grease trap may be used. In this instance, the grease trap shall be installed in a separate area from the food handling area and in a location that is easily accessible for cleaning, maintenance, and inspection. The use of this smaller mechanical grease interceptor shall be approved by the City.
- L. All property owners or Utility users with grease interceptors shall have sole responsibility for the installation and maintenance of the grease interceptor. They shall be responsible for the proper removal and disposal, by appropriate means, of the captured material in the interceptors.
- M. The City has the right to inspect all grease interceptors that are upstream from City owned sewers. Any person, business or owner that are found to be responsible for the discharging of fats, oils and grease shall be charged for the cost of rectifying any and all issues created by the discharge.

SECTION VI - STORM SEWERS

VI-1 FOOTING DRAINAGE DISCHARGE COLLECTION SYSTEM

- A. A footing drainage discharge collection system shall be designed and installed in all new developments where the seasonal high groundwater is within 4 feet of existing grade.
- B. The collection system shall include access taps for each lot.

VI-2 STORM SEWER PIPE

The following pipe materials may be used for installations up to ten (10.0) feet of cover. For cover exceeding ten (10) feet, a design of material, performed by a Professional Engineer, shall be submitted to the office of the Department of Engineering for review and approval.

- A. Reinforced Concrete Pipe (RCP)
 - 1. Reinforced Concrete Pipe will meet the requirements of ASTM C76, Class III, and Wall B each pipe will be marked with this information. Pipe ends shall have O-ring grooves provided during manufacturing process. Each pipe will be marked with this information.
 - 2. Rubber O-ring gaskets and joints of concrete pipe will meet the requirements of ASTM C443.
 - 3. Pipe bedding Detail 'A' or 'B' will be required.
 - 3. Pipe shall have a smooth wall interior.
- B. Ductile Iron Pipe (DI)
 - 1. Ductile Iron Pipe shall meet the requirements of ANSI-AWWA C150/A21.50 and C151/A21.51 pressure classification 350 psi minimum. Each pipe will be marked with this information.
 - a. Joints of the Ductile Iron Pipe will meet ANSI/AWWA C11/A21.11.
 - b. Pipe bedding Detail 'A' or 'B' will be required.
 - c. Pipe shall have a smooth wall interior with cement lining per ANSI/AWWA A21.4/C104
- C. Vitrified Clay Pipe (VC)
 - 1. Vitrified Clay Pipe will meet the requirements of ANSI/ASTM C-700 extra strength. Each pipe will be marked with this information.
 - 2. Joints of vitrified clay pipe will meet the requirements of ANSI/ASTM C425.
 - 3. Pipe bedding details 'A' or 'B' will be marked.
 - 4. Pipe shall have a smooth wall interior.
- D. Polyvinyl Chloride Pipe (PVC)
 - 1. Polyvinyl Chloride Pipe, sizes 4 inches through 24 inches in diameter shall meet the requirements of ASTM D3034, SDR 35 and have a minimum pipe stiffness of 46 PSI. Each pipe will be marked with this information.
 - 2. The pipe shall be jointed with an integral bell, bell and spigot type rubber gasket joint. Gasket will conform to ASTM D3212 and F477. Fittings will conform to ASTM D3212.
 - 3. Pipe bedding Detail 'B' will be required.
 - 4. Pipe shall have a smooth wall interior.
 - 5. The maximum acceptable pipe deflection after installation is five percent (5%) of the nominal pipe diameter The pipe shall be tested by the contractor 30 days or greater after the installation is complete and upon written notification to the City. The deflection test shall be completed with a 9-point mandrel for maximum deflection. The mandrel shall be pulled manually and no force pull on the mandrel will be permitted. The deflection test shall be witnessed and certified by a Professional Engineer and submitted to the office of the Department of Engineering. If the pipe fails the deflection test, the pipe shall be excavated, removed, and discarded. New pipe shall be installed and retested per the above.
 - 6. A-2000 PVC pipe shall meet the requirements of ASTM F949. It shall be smooth interior and can be used up to 36 inches in diameter.

- E. Smooth-Lined Corrugated Polyvinyl Chloride Pipe (SLCPVC)
1. Smooth-Lined Corrugated Polyvinyl Chloride Pipe, sizes 4 inches through 30 inches in diameter shall meet the requirements of ASTM F-949. Each pipe will be marked with this information. The pipe stiffness will be a minimum of 46 PSI. The pipe manufacturer will certify compliance with these requirements.
 2. The joint will be water tight with integral factory-formed bell and spigot with a rubber gasket in accordance with ASTM D3212 and F477.
 3. The gasket on the spigot end of the pipe shall be lubricated prior to insertion as required by the pipe manufacturer.
 4. Pipe bedding Detail 'B' will be required.
 5. The maximum acceptable pipe deflection after installation is five percent (5%) of the nominal pipe diameter. The pipe shall be tested by the contractor 30 days or greater after the installation is complete and upon written notification to the Department of Engineering. The deflection test shall be completed with a 9-point mandrel for maximum deflection. The mandrel shall be pulled manually and no force pull on the mandrel will be permitted. The deflection test shall be witnessed and certified by a Professional Engineer and submitted to the office of the Department of Engineering. If the pipe fails the deflection test, the pipe shall be excavated, removed, and discarded. New pipe shall be installed and retested per the above.
- F. Smooth-Lined Corrugated Polyethylene Pipe (SLCP)
1. Smooth-Lined Corrugated Polyethylene Pipe, commonly referred to as "HDPE" shall only be acceptable for use as a perforated pipe. Pipe bedding shall be in accordance with Detail VI-12 – Perforated Pipe Detail.
 2. Smooth-Lined Corrugated Polyethylene Pipe sizes 4 inches through 10 inches in diameter shall meet the requirements of AASHTO M-252, Type S. Pipe sizes 12 inches through 36 inches shall meet the requirements of AASHTO M-294, Type S. Each pipe will be marked with this information. The polyethylene pipe will be produced from resins meeting the requirements of ASTM 3350 with a Cell Class of 324420C. The pipe manufacturer will certify compliance with these requirements.
 3. The joint will be a self-locking polyethylene integral bell or bell sleeve. It shall be watertight in accordance with ASTM D3212. The rubber gasket shall meet the requirements of ASTM F477.
 4. The gasket on the spigot end of the pipe shall be lubricated prior to insertion as required by the pipe manufacturer.

5. The maximum acceptable pipe deflection after installation is five percent (5%) of the nominal pipe diameter. The pipe shall be tested by the contractor 30 days or greater after the installation is complete and upon written notification to the City. The deflection test shall be completed with a 9-point mandrel for maximum deflection. The mandrel shall be pulled manually and no force pull on the mandrel will be permitted. The deflection test shall be witnessed and certified by a Professional Engineer and submitted to the office of the Department of Engineering. If the pipe fails the deflection test, the pipe shall be excavated, removed, and discarded. New pipe shall be installed and retested per the above.
- G. High Density Polyethylene Pipe (HDPE)
1. High Density Polyethylene Pipe shall meet the requirements of AASHTO M294.
 2. It shall be smooth interior and only utilized as perforated pipe up to 36 inches in diameter
 3. HDPE pipe shall be used only with Engineer's approval.

VI-3 STORM SEWER CASTINGS

- A. Manhole, inlet, and catch basin castings shall be as specified in the Mishawaka Standard Drawings or as approved by the Department of Engineering.
- B. All storm sewer catch basin and inlet castings shall be NPDES Phase II compliant with a permanently cast fish image and "DUMP NO WASTE! DRAINS TO WATERWAYS" message.
- C. All old castings that are removed or replaced during construction shall be turned over to the City.

SECTION VII - UTILITIES

VII-1 WATER UTILITIES

- A. Water utilities shall be installed and tested per the "General Construction Specifications" for the Mishawaka Utilities Water Division.

VII-2 UTILITIES IN CASING (JACK/BORE METHODS)

- A. Materials
 1. Carrier pipes used in the crossings shall be the same material as that adjacent to the crossings. The carrier pipe shall be installed per the lines and grades shown on the plans or as directed.
 2. The Casing pipe shall be as shown on the plans. Steel casing shall have a minimum thickness as shown in the Pipe in Casing Detail, Detail VII-1, in the Standard Details.

3. All utilities installed under a railroad right-of-way shall be in accordance with the specifications and requirements of the railroad having jurisdiction.
- B. Installation
1. The casing pipe shall be so constructed as to prevent leakage of any substance from the casing throughout its length except at the ends of the casing, which must be blocked to prevent the entrance of foreign material. Casing shall be installed to prevent the formation of a waterway under the Pipe, and with an even bearing throughout its length, and shall slope to one end as shown on the plans.
 2. The casing pipe shall be pushed into the embankment with jacks and shall have a boring auger rotating within the pipe to remove the spoil. The front of the pipe shall be provided with mechanical arrangements or devices that will prevent the auger and cutting head from leading the pipe by more than 1/2 inch. Under no circumstances will more than 1/2 inch of unsupported excavation be permitted ahead of the casing pipe. The face of the cutting head shall be arranged to provide reasonable obstruction to the free flow of soft or poor material into the casing.
 3. The use of water or other liquids to facilitate casing emplacement and spoil removal is prohibited.
 4. If an obstruction is encountered during installation to stop the forward action of the pipe, and it is evident that it is impossible to advance the pipe, operations will cease and the casing shall be abandoned in place and completely filled with grout per INDOT Specifications 716.03b.
 5. All installations shall have a bored hole essentially the same as the outside diameter of the pipe, plus the thickness of the protective coating. If voids should develop or if the bored hole is greater than the outside diameter of the casing by more than one inch, grouting shall be required to fill the voids.
 6. When a gravity flow carrier pipe is placed inside the casing pipe, the carrier pipe shall be secured to the lines, slopes, and grades shown on the plans and then the void between the two pipes shall be filled with a flowable grout, unless otherwise indicated on the plans, so that the carrier pipe remains in a fixed position.

SECTION VIII - MAINTENANCE OF TRAFFIC

VIII-1 STREET SIGNS

- A. The developer is responsible for Payment to the City of Mishawaka prior to the Installation of All traffic control signing and street name signs on all streets to be dedicated to the City. All traffic control devices are to be in conformance with the MUTCD

VIII-2 CONSTRUCTION SIGNAGE

- A. A Maintenance of Traffic plan must be submitted for City approval at least five (5) working days prior to restriction or closure of any street. The plan shall include anticipated date and times of restriction or closure as well as emergency contact numbers. Note: Additional traffic control may be needed for High Volume Streets, as listed in ordinance.
- B. The contractor is responsible for proper traffic control and warning signing and devices as required by the MUTCD, for the duration of construction on any public street. Failure to do so will result in the City providing the necessary equipment and charging the contractor with all related costs.

SECTION IX – TRAFFIC ENGINEERING

IX-1 VIDEO DETECTION SYSTEM

- A. Comprised of a color camera, zoom lens, and machine vision processor (MVP) integrated into a single unit.
- B. Each MVP shall be capable of controlling iris adjustment and lighting control individually.
- C. Units shall be IP addressable for system networking from TOC.
- D. Twisted pair cable shall be used for transmitting processed video and data from MVP to signal cabinet.
- E. Interface to signal controller shall be by TS2 Mini Hub.
- F. Autoscope Solo Pro II shall be used.
- G. All equipment must be approved by the Engineer prior to ordering from the manufacturer.

IX-2 OPTICAL PREEMPTION TRAFFIC SIGNAL CONTROL SYSTEM

- A. System hardware
 - 1. The optical preemption traffic signal control system shall use optical communication technology with encoded data transmissions to verify authorized vehicle actuations of the system.
 - 2. This optical communication technology will work in concert with the local traffic signal controller at the intersection and will request the controller to advance to and/or hold a desired traffic signal display.
 - 3. System shall be 3M Opticom or approved equal.
 - 4. All equipment must be approved by the Engineer prior to ordering from the manufacturer.

IX-3 SPREAD SPECTRUM RADIO INTERCONNECT

- A. Intuicom Spread Spectrum Radio System shall be used as the radio interconnect with Engineer's approval.

- B. Intuicom Spread Spectrum Radio System shall include (but not limited to):
 - 1. Antenna
 - 2. Antenna hardware
 - 3. LMR-400 coax
 - 4. Coax connectors
 - 5. Poly phaser
 - 6. Connecting cables inside of cabinet
 - 7. Radio
 - 8. Interface
- C. Requests to use radio equipment other than Intuicom shall be submitted and demonstrated to be able to communicate with existing radio locations.
- D. All equipment must be approved by the Engineer prior to ordering from manufacturer

IX-4 SIGNAL HEAD SPECIFICATION

- A. All signal heads shall be polycarbonate and include LED inserts for all colors and arrows.
- B. Pedestrian signals shall be aluminum or polycarbonate and include LED inserts with countdown.
- C. LED inserts shall be GELcore or approved equal.

IX-5 UNINTERRUPTIBLE POWER SUPPLY

- A. Unit shall be capable of handling surges and spikes present in normal utility power, provide up to 12 hours battery back up during power outages, and have the capabilities of being remotely monitored.
- B. Unit shall be housed in a separate cabinet and connected/mounted to the side of traffic controller cabinet.
- C. An automatic transfer switch shall be included.
- D. Unit to be model Novus FXM 1100 as manufactured by Alpha Technologies or approved equal.
- E. All components must be interchangeable with existing battery units.
- F. All equipment must be approved by the Engineer prior to ordering from manufacturer.

IX-6 CONTROLLER

- A. It shall be a 12-phase ts2 controller and the P-cabinet shall be NEMA TS2 Type 1.
- B. The controller and cabinet shall be equipped with the necessary equipment for fiber optic communication.
- C. The controller shall be compatible with existing City of Mishawaka system software and master controllers.
- D. It shall be Econolite ASC/2 series, manufactured by Econolite Control Products, Inc.

- E. All equipment must be approved by the Engineer prior to ordering from manufacturer.

IX-7 SPECIAL TRAFFIC SIGNAL COMPONENT COLOR

- A. When directed by the City, traffic signal components are to be finished as specified below in an “Architectural Bronze” color. Special care shall be taken by the Contractor to ensure similar colors are used for the different components.
 - 1. Aluminum mast arm poles, mast arms, and appurtenances shall be factory anodized with an “Architectural Bronze” finish.
 - 2. Steel Strain Poles and appurtenances shall be factory galvanized and powder coated in “Architectural Bronze.”
 - a. All components shall be galvanized and finished in accordance with ASTM A 123.
 - b. The powder coating shall be a urethane or triglycidyl isocyanate (TGIC) polyester powder.
 - c. The powder coating shall be applied in accordance with all requirements of the manufacturer of the powder coating material to a minimum dry film thickness of 2 mils (0.002”).
 - 3. Aluminum controller cabinets and other traffic signal appurtenances shall be powder coated “Architectural Bronze.”
 - a. The powder coating shall be a urethane or triglycidyl isocyanate (TGIC) polyester powder.
 - b. The powder coating shall be applied in accordance with all requirements of the manufacturer of the powder coating material to a minimum dry film thickness of 2 mils (0.002”).
 - 4. Traffic signal heads and pedestrian signals required to be “Architectural Bronze” in color shall be aluminum and powder coated.
 - a. The powder coating shall be a urethane or triglycidyl isocyanate (TGIC) polyester powder.
 - b. The powder coating shall be applied in accordance with all requirements of the manufacturer of the powder coating material to a minimum dry film thickness of 2 mils (0.002”).

SECTION IX – LIGHTING/ELECTRICAL

(Reserved for future)

END OF STANDARD SPECIFICATIONS